

**CERTIFICATE OF  
ANNUAL ENERGY MANAGEMENT AND ENERGY CONSERVATION**

**To Whomsoever It May Concern**

**Name of the premises:** KKR &KSR INSTITUTE OF TECHNOLOGY AND SCIENCES

**Address:** Vinjanampadu, Vatticherukuru – 522017, Guntur Dist.Andhra Pradesh, INDIA.

This is to certify that the data furnished below are derived from the audit conducted during the assessment period from 1<sup>st</sup> April 2023 to 31<sup>st</sup> March 2024.

**Annual Power Consumption and Alternate Source of Energy (Annexure - I):**

Annual Power Requirement Kwh	: 3,74,770 Kwh
Annual Power Requirement met by Renewable Energy Sources	: 1,79,802 Kwh
Percentage of Renewable Energy used	: 47.98 %
Percentage of Energy through other sources	: 52.02 %

**Annual Power Consumption for Lighting (Annexure - II):**

Annual Lighting Power Requirement Kwh	: 50100.50 Kwh
Annual Lighting Power Requirement met through LED bulbs Kwh	: 38580.50 Kwh
Percentage Lighting through LED bulbs	: 77.01 %
Percentage lighting through other sources	: 22.99 %

Signature:



Name: VKVN PRASAD

Designation: Energy Auditor

Seal:

**VKVN PRASAD**  
BSET, MBA - Power Management  
Certified Energy Auditor cum Energy Manager  
(BEE) EA - 18325

Date: 23/07/2024

